


SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to SS-EN ISO 354 and ISO 20189

Client:	OFFECCT		
Object:	Soundsticks®		
Size [mm]:	w = 1240	h = 95	d = 95

1/3 octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.1
125	0.2
250	0.6
500	1.4
1000	2.2
2000	2.7
4000	3
N ₁₀ = 7	

**CONDITIONS**

Date of test:	2019-01-31	Object volume:	0.01 m ³
Date:	2019-01-31	Rev. room volume:	200 m ³

Test report: Akustikverkstan 18-732-M1
 Signature: Carl Nyqvist