


**SOUND ABSORPTION AREA FOR OBJECT**

Measured and evaluated according to SS-EN ISO 354 and ISO 20189

Client:	OFFECCT		
Object:	Soundsticks® Cluster		
Size [mm]:	w = 1240	h = 95	d = 95

1/3 octave band (Hz)	Equivalent sound absorption area / unit (m <sup>2</sup> Sabine)
63	0.1
125	0.1
250	0.6
500	1.4
1000	2.1
2000	2.5
4000	2.6
N <sub>10</sub> = 7	



**CONDITIONS**

Date of test:	2019-01-23	Object volume:	0.01 m <sup>3</sup>
Date:	2019-01-31	Rev. room volume:	200 m <sup>3</sup>

Test report: Akustikverkstan 18-732-M2  
 Signature: Carl Nyqvist