




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Abstracta		
Object:	Soneo Floor		
Size [mm]:	w = 800	h = 1700	d = 50

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.3
125	0.4
250	1.1
500	1.9
1000	2.2
2000	2.2
4000	2.3
N₁₀ = 5.3	



ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 18-720-R2-M18	2018-12-13

