




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Abstracta		
Object:	Trumpet 1040		
Size [mm]:	w = 515	h = 1040	d = 80

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.08
125	0.1
250	0.4
500	0.5
1000	0.5
2000	0.5
4000	0.6
N ₁₀ = 20	



ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 17-094-R1	2017-05-10

