




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Nordgröna		
Object:	Reindeer Moss CONVEX		
Size [mm]:	w = 600	h = 600	d = 120

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0
125	0.1
250	0.3
500	0.5
1000	0.6
2000	0.6
4000	0.6
N ₁₀ = 20	



ORIGINAL TEST REPORT	DATE OF REPORT
19-725-M5	2019-12-11

