
SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:			
Object:	Globuz		
Size [mm]:	w = 1100	h = 50	d =

Octave band (Hz)	Equivalent sound absorption area / unit (m^2Sabine)
63	0.1
125	0.2
250	0.6
500	1.1
1000	1.3
2000	1.3
4000	1.2
N_{10} =	9.1



ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 19-728-M7	2019-07-10

Acoustic Facts Scandinavia AB

Kinnegatan 23, 531 33 Lidköping

acousticfacts.com