
SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:			
Object:	Mollis		
Size [mm]:	w = 2400	h = 1200	d = 50

Octave band (Hz)	Equivalent sound absorption area / unit (m^2Sabine)
63	0.3
125	0.9
250	2
500	3.2
1000	3.9
2000	3.6
4000	3.4
N_{10} =	3.1



ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 19-728-M5	2019-07-10

Acoustic Facts Scandinavia AB

Kinnegatan 23, 531 33 Lidköping

acousticfacts.com