




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Kinnarps		
Object:	Vibe (floor screen)		
Size [mm]:	w = 1165	h = 1200	d = 40

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.3
125	0.4
250	1.1
500	1.6
1000	2
2000	2.2
4000	2.4
N₁₀ = 6.3	



ORIGINAL TEST REPORT	DATE OF REPORT
19-713-M7	2019-05-06

