




# SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

<b>Client:</b>	Kinnarps		
<b>Object:</b>	Vibe (floor screen)		
<b>Size [mm]:</b>	w = 1165	h = 1800	d = 40

Octave band (Hz)	Equivalent sound absorption area / unit (m <sup>2</sup> Sabine)
63	0.4
125	0.6
250	1.6
500	2.3
1000	3
2000	3.1
4000	3.2
<b>N<sub>10</sub> = 4.3</b>	



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF REPORT</b>
19-713-M8	2019-05-06

