




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Kinnarps		
Object:	Vibe (desk screen)		
Size [mm]:	w = 2000	h = 650	d = 40

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.3
125	0.37
250	1
500	1.5
1000	1.9
2000	2
4000	2.3
N₁₀ = 6.7	



ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 21-723-M8	2021-05-26

