
SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Decibel AB		
Object:	Frequency (6 pcs)		
Size [mm]:	w = 600	h = 600	d = 80

Octave band (Hz)	Equivalent sound absorption area / unit (m^2Sabine)
63	0.23
125	0.88
250	2.4
500	2.8
1000	2.7
2000	2.7
4000	2.7
N_{10} =	3.7



ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 21-738-M7	2021-10-29

Acoustic Facts Scandinavia AB

Kinnegatan 23, 531 33 Lidköping

acousticfacts.com