




# SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

<b>Client:</b>	Decibel AB		
<b>Object:</b>	Cubic 200		
<b>Size [mm]:</b>	w = 400	h = 400	d = 2000

Octave band (Hz)	Equivalent sound absorption area / unit (m <sup>2</sup> Sabine)
63	0.4
125	1.2
250	2
500	2.6
1000	3.2
2000	3.2
4000	3.1
<b>N<sub>10</sub> = 3.8</b>	



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF REPORT</b>
Akustikverkstan report 20-702-M1	2020-01-14

