


SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Boom Interior		
Object:	Xrozz Integrated		
Size [mm]:	w = 800	h = 1600	d = 40

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.4
125	0.6
250	0.9
500	1.2
1000	1.3
2000	1.7
4000	1.9
N₁₀ = 8.3	



ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 18-701-M5	2018-08-23

