
SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Boom Interior		
Object:	Xrozz Absorption Plus		
Size [mm]:	w = 600	h = 2000	d = 50

Octave band (Hz)	Equivalent sound absorption area / unit (m^2Sabine)
63	0.3
125	0.45
250	0.91
500	1.5
1000	1.9
2000	2.1
4000	2.3
	N_{10} = 6.7

Equivalent sound absorption area / unit



Frequency, Hz

ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 21-720-M7	2021-07-12

Acoustic Facts Scandinavia AB

Kinnegatan 23, 531 33 Lidköping

acousticfacts.com