
SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Boom Interior		
Object:	Xrozz Absorption Plus		
Size [mm]:	w = 800	h = 1000	d = 50

Octave band (Hz)	Equivalent sound absorption area / unit (m^2Sabine)
63	0.17
125	0.28
250	0.62
500	0.97
1000	1.3
2000	1.4
4000	1.5
	N_{10} = 10.3



ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 21-720-M9	2021-07-12

Acoustic Facts Scandinavia AB

Kinnegatan 23, 531 33 Lidköping

acousticfacts.com