




# SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

<b>Client:</b>	Abstracta		
<b>Object:</b>	Moon lighting		
<b>Size [mm]:</b>	w = 525	h = 525	d = 550

Octave band (Hz)	Equivalent sound absorption area / unit (m <sup>2</sup> Sabine)
63	
125	0.27
250	0.51
500	0.61
1000	0.68
2000	0.76
4000	0.88
<b>N<sub>10</sub> = 16.4</b>	



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF REPORT</b>
KTH report 20230127.1	2023-01-27

