
SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Götessons/ Gotessons, Akustikmiljö / Am Acoustics		
Object:	PlainPanel with EcoSund (2 groups of 6 pcs)		
Size [mm]:	w = 58	h = 58	d = 21

Octave band (Hz)	Equivalent sound absorption area / unit (m^2Sabine)
63	0.22
125	0.6
250	1.4
500	1.8
1000	2.1
2000	2.3
4000	2.3
N_{10} =	5.6

Equivalent sound absorption area / unit



Frequency, Hz

ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 2633-R1-M2	2023-03-08

Acoustic Facts Scandinavia AB

Kinnegatan 23, 531 33 Lidköping

acousticfacts.com