




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Götessons/ Gotessons, Akustikmiljö / Am Acoustics		
Object:	Effekt		
Size [mm]:	w = 1200	h = 300	d = 50

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.1
125	0.2
250	0.5
500	0.7
1000	0.8
2000	0.8
4000	0.8
N₁₀ = 14.3	



ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 16-239-M10	2017-03-09

