




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Akustikmiljö / Am Acoustics		
Object:	Single		
Size [mm]:	w = 1200	h = 900	d = 50

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.1
125	0.34
250	0.76
500	1.2
1000	1.33
2000	1.1
4000	1.04
N₁₀ = 9.6	



ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 16-239-M4	2016-11-25

