




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Akustikmiljö / Am Acoustics		
Object:	Single		
Size [mm]:	w = 600	h = 600	d = 50

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.03
125	0.12
250	0.27
500	0.45
1000	0.46
2000	0.38
4000	0.37
N ₁₀ = 27	



ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 16-239-M3	2016-11-25

