




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Götessons/ Gotessons		
Object:	HALF A HUT WITH FRONT SCREENS		
Size [mm]:	w = 1880	h = 2270	d = 900

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	2.6
125	2.8
250	5.6
500	7.3
1000	8.1
2000	8.9
4000	10.1
N₁₀ = 1.4	



ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 17-321-M6	2017-12-08

