




# SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

<b>Client:</b>	Götessons/ Gotessons		
<b>Object:</b>	HALF A HUT WITH FRONT SCREENS AND DOOR		
<b>Size [mm]:</b>	w = 1880	h = 2270	d = 970

Octave band (Hz)	Equivalent sound absorption area / unit (m <sup>2</sup> Sabine)
63	2.6
125	2.7
250	5.2
500	6.5
1000	7.2
2000	8
4000	9.4
<b>N<sub>10</sub> = 1.5</b>	



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF REPORT</b>
Akustikverkstan report 17-321-M7	2017-12-08

