




# SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

<b>Client:</b>	Götessons/ Gotessons		
<b>Object:</b>	Hang Over		
<b>Size [mm]:</b>	w = 810	h = 690	d = 130

Octave band (Hz)	Equivalent sound absorption area / unit (m <sup>2</sup> Sabine)
63	0.1
125	0.1
250	0.3
500	0.6
1000	0.8
2000	0.9
4000	1
<b>N<sub>10</sub> = 16.7</b>	



<b>ORIGINAL TEST REPORT</b>	<b>DATE OF REPORT</b>
Akustikverkstan report 17-321-M13	2017-12-08

