


## SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to SS-EN ISO 354 and ISO 20189

Client:	Decibel AB		
Object:	Hertz 6 pcs		
Size [mm]:	w = 1800	h = 1200	d = 60

1/3 octave band (Hz)	Equivalent sound absorption area / unit (m <sup>2</sup> Sabine)
63	0.1
125	1
250	2.2
500	2.8
1000	2.9
2000	2.6
4000	2.4
N <sub>10</sub> = 4	



### CONDITIONS

Date of test:	2018-06-11	Object volume:	0.13	m <sup>3</sup>
Date:	2018-10-02	Rev. room volume:	200	m <sup>3</sup>

Test report: Akustikverskan 18-051-M13  
 Signature: Carl Nyqvist