


SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to SS-EN ISO 354 and ISO 20189

Client:	Decibel AB		
Object:	Hertz 6 pcs		
Size [mm]:	w = 1800	h = 1200	d = 40

1/3 octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.1
125	0.6
250	1.5
500	2.6
1000	2.9
2000	2.5
4000	2.2
N ₁₀ = 5	



CONDITIONS

Date of test:	2018-06-11	Object volume:	0.09	m ³
Date:	2018-10-10	Rev. room volume:	200	m ³

Test report: Akustikverkstan report 18-051-M12
 Signature: Carl Nyqvist