



SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Decibel AB		
Object:	Hertz 6 pcs		
Size [mm]:	w = 1800	h = 1200	d = 40

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)	Equivalent sound absorption area / unit
63	0.1	
125	0.6	
250	1.5	
500	2.6	
1000	2.9	
2000	2.5	
4000	2.2	
	N₁₀ =	4.5

Frequency, Hz

ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 18-051-M12	2018-10-22

