
SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Glimakra Of Sweden		
Object:	Limbus Concept Workstation		
Size [mm]:	w = 1260	h = 1600	d = 1600

Octave band (Hz)	Equivalent sound absorption area / unit (m^2Sabine)
63	1.36
125	2.35
250	2.71
500	4.48
1000	7.32
2000	8.77
4000	8.98
N_{10} =	2.2



ORIGINAL TEST REPORT	DATE OF TEST
sp report 10188024	2013-11-04

Acoustic Facts Scandinavia AB

Kinnegatan 23, 531 33 Lidköping

acousticfacts.com