


## SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to SS-EN ISO 354 and ISO 20189

Client:	Abstracta		
Object:	Lily		
Size [mm]:	w = 900	h = 900	d = 10

1/3 octave band (Hz)	Equivalent sound absorption area / unit (m <sup>2</sup> Sabine)
63	0
125	0.2
250	0.4
500	0.7
1000	1
2000	1.3
4000	1.3
N <sub>10</sub> = 14	



### CONDITIONS

Date of test:	2019-01-14	Object volume:	0.01	m <sup>3</sup>
Date:	2019-01-20	Rev. room volume:	200	m <sup>3</sup>

Test report: Akustikverkstan report 18-720-M12  
 Signature: Johan Jernstedt