
SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Abstracta		
Object:	Scala Wall		
Size [mm]:	w = 1207	h = 1600	d = 20

Octave band (Hz)	Equivalent sound absorption area / unit (m^2Sabine)
63	0
125	0.32
250	1.37
500	2.53
1000	2.38
2000	2.05
4000	2.27
N_{10} =	4.9



ORIGINAL TEST REPORT	DATE OF REPORT
KTH-MWL LW20170314_R2	2017-03-14

Acoustic Facts Scandinavia AB

Kinnegatan 23, 531 33 Lidköping

acousticfacts.com