
SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Abstracta		
Object:	Soneo Wall		
Size [mm]:	w = 1000	h = 1000	d = 30

Octave band (Hz)	Equivalent sound absorption area / unit (m^2Sabine)
63	0.01
125	0.14
250	0.12
500	0.25
1000	0.32
2000	0.34
4000	0.37
	N_{10} = 40

Equivalent sound absorption area / unit



Frequency, Hz

ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 17-360-M6	2018-01-16

Acoustic Facts Scandinavia AB

Kinnegatan 23, 531 33 Lidköping

acousticfacts.com