


SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to SS-EN ISO 354 and ISO 20189

Client:	Abstracta		
Object:	Sky		
Size [mm]:	w = 846	h = 591	d = 120

1/3 octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0
125	0.09
250	0.29
500	0.32
1000	0.4
2000	0.42
4000	0.49
N ₁₀ = 31	



CONDITIONS

Date of test:	2018-09-23	Object volume:	0.06	m ³
Date:	2019-02-28	Rev. room volume:	200	m ³

Test report: KTH-MWL ABSTRACTA SKY 20180923
 Signature: Lars Wester