




SOUND ABSORPTION AREA FOR OBJECT

Measured and evaluated according to ISO 354 and ISO 20189

Client:	Abstracta		
Object:	Jetty		
Size [mm]:	w = 4800	h = 1400	d = 740

Octave band (Hz)	Equivalent sound absorption area / unit (m ² Sabine)
63	0.6
125	1
250	1.4
500	2.2
1000	2.3
2000	2.2
4000	2.3
N₁₀ = 4.5	



ORIGINAL TEST REPORT	DATE OF REPORT
Akustikverkstan report 17-360-M9	2018-01-16

